

RECORD OF FIRE SAFETY EQUIPMENT AND TRAINING

FIRE ALARM SYSTEM - RECORD OF TESTS

The fire alarm system shall be tested monthly, using a different call point for each successive test to ensure that it operates satisfactorily and the results of such tests recorded.

The system shall be maintained in efficient working order in accordance with British Standards 5839, Part 1.

Date	Fire Alarm		Automatic Door Releases	Automatic Detectors		Remedial Action Taken	Fault Cleared Yes/No	Signature
	Call Point Location or No.	Satisfactory Yes/No	Satisfactory Yes/No	Location or No.	Satisfactory Yes/No			

EMERGENCY LIGHTING SYSTEM - RECORD OF TESTS

Emergency Lighting Systems shall be tested in accordance with British Standard 5266, Part 1.

Central Battery Systems: Twice a year the batteries should be arranged to supply the emergency lighting system by simulation of a failure of the normal lighting supply for a continuous period of at least one hour.

During this period all luminaires and/or signs should be checked for proper function.

At the end of the test period the system should be restored to normal operation and the charging arrangements checked for proper function.

Self contained luminaires and internally illuminated signs: Once a month each luminair and signs should be energised from its batteries for a period of at least one hour.

Date	Duration of Test	Result of Test	Fault (Specify)	Fault Cleared	Signature